


Paul Hodge

From: Aaron Herzon
Sent: Friday, June 03, 2005 3:10 PM
To: Paul Hodge
Subject: Drip Leg Requirement

Paul,

In our instructions for the M3-series furnace on page 20, Nordyne suggests the use of a drip leg (sediment trap) in the gas supply piping to the furnace. This is not a requirement. However, Nordyne does require that the furnace be installed in accordance with any applicable local codes and requirements, or, in the absence of local codes, the installation must be in compliance with the National Fuel Gas Code. Most codes governing the installation of gas piping call out a requirement for a sediment trap (or drip leg). For example, Section 5.5.7 of the National Fuel Gas Code.

Sincerely,

A handwritten signature in black ink that reads "Aaron Herzon". The signature is stylized with a long horizontal line extending to the right.

Aaron Herzon, PE
Engineering Director
Nordyne, INC
636-561-7476
herzona@nordyne.com