

TEST REPORT

DATE: 04/15/2013 TEST NUMBER: 156635

	ASTM	C1028-96	Test	Method	for	Determining	the	Static
TEST METHOD CONDUCTED	Coeffi Metho		tion b	y the Horiz	onta	l Dynamomete	er Pull	l-Meter

DESCRIPTION OF TEST SAMPLE			
IDENTIFICATION	Mohawk 8mm Laminate		
COLOR	Carmaroon Acacia		
CONSTRUCTION	Laminate Flooring		

GENERAL PRINCIPLE

This test determines the static coefficient of friction of tile or other surfaces using a neolite heel assembly.

A neolite heel assembly with a 50 pound load is pulled horizontally with a dynamometer to measure the force required to cause the assembly to slip. After the sample is tested, measurements are calculated and reported as the static coefficient of friction.

TEST RESULTS

|--|

HEEL ASSEMBLY CONDITION	STATIC COEFFICIENT OF FRICTION			
Dry	0.77			

APPROVED BY:

Day Willing

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical of similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.

714 Glenwood Place Dalton, GA 30721 Phone: 706-226-3283 Fax: 706-226-6787 email: protest@optilink.us